

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC22107356590

Valid from: Aug.24,2022

Valid until: Aug.23,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT Huanyu High Tech. Co. , Ltd.
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Huanyu High Tech. Co. , Ltd.
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Huanyu High Tech. Co. , Ltd.
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Moulded case circuit-breaker
HUM17M-63G ; HUM17MA-63G: Uimp:4kV ; Ui : 690V ; Ue : 400V ; In : 6A , 10A , 16A , 20A , 25A , 32A , 40A , 50A , 63A ; Over-current ReleaseType : Thermal magnetic type : HUM17M-63G, Single magnet : HUM17MA-63G ; Ics=Icu=6kA ; Selectivity categories : A ; 3P、4P : Suitable for isolation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.2-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE